

## Consultants Advice Notice

project	<b>HIGH STREET COHOUSING</b>	file ref.	1402-F18-30.DOC
date	<b>29.08.19</b>	pages (inc attach).	<b>6</b>
issued by:	<b>T ROSS</b>	Approved TR	
issued to:	<input checked="" type="checkbox"/> <b>REECE BUILDING CONSULTANTS - STEFAN BOX</b>		
copies to:	<input checked="" type="checkbox"/> <b>UCOL, STEVENSON &amp; WILLIAMS</b>		

Architype Ltd.  
ASB House, Level 6  
248 Cumberland Street  
PO Box 5510, Dunedin 9058

(t) 03-552-0621  
info@architype.co.nz  
www.architype.co.nz

Consecutive No. **CAN-030**

*This advice notice is issued to clarify queries as listed. A CI shall be issued by the project manager where advice is other than a clarification.*

### **RFI: Questions from Aotea**

1. Hotwater system for the 'M' units is to be a shared Aquarian 275L outdoor heat pump water heater with separate flow meters. Unit supplied from the main common house distribution board, electricity consumption to be metered separately.
2. Common House external lighting – Additional light required by the Montpellier St entry. Refer attached Common House drawing A1-12.
3. There is no ventilation system in the common house area
4. Appliance specs for common kitchen  
Steriliser – Starline M1 or similar  
Cooker - Bosch 90cm Gas Range Cooker HSB738357A or similar
5. MVHR control panel locations. Refer updated plans Common House A1-11 & A1-12 Alva A1-08, High A1-19 & A1-20. Connect to ventilation systems with CAT 6
6. Location of Common House distribution board has been updated. Refer Common House A1-12
7. Drawing Alva A1-16 & High A1-29 indicate the general layout of the tanks. Pumps and power meters to be coordinated with plumber.
8. TV outlets are to be installed as per the original tender. Refer amended drawings.